

Polycleanse Usage Chart

5 - Gal Pail = 18 lbs. / 8.16 kg of Polylok Cleanse Powder

Usage Instructions

Sluggish Septic & Drains

- Shock treat septic system with 1 lb. (4 cups) / 0.45 kg (approx. 950 ml). Flush the treatment down the toilet leading to the septic tank.
- For slow running drains, a shock treatment of 1 oz. (1/4 cup) / 28 g (approx. 60 ml) per night for 10 days is needed.
- Treat both when the least amount of water usage will occur.

Routine Treatments for Septic Systems, ATUs, Cesspools & Drains

- Treat all types of septic systems every 3 months with 6 oz. (1 1/2 cups) / 170 g (approx. 355 ml) of product. Flush treatment down the toilet.
- Treat each drain monthly by pouring 1 oz. (1/4 cup) / 28 g (approx. 60 ml) down each drain. Flush with small amount of water.
- All treatments should be done when the least amount of water usage occurs.

Grease Trap Daily Maintenance

Follow this chart:

Grease Trap Size	Daily Dosage
1 - 500 gallon trap	1/2 oz. daily / 57 g daily / 14 g daily
501 - 1,200 gallon trap	1 oz. daily / 28 g daily
1,201 - 2,500 gallon trap	2 oz. daily / 57 g daily
2,501 - 5,000 gallon trap	3 oz. daily / 85 g daily

Dumping Stations & Lift Stations

- Treat dumping & lift stations with 4 oz. weekly (1 cup) / 113 g weekly (approx. 240 ml) or as needed.

Municipal Sewer Laterals

Treat sewer laterals during times of low water flow.

Pipe Diameter	Dosage
6 - 16 inches	1 lb. per 400 ft. / 0.45 kg per 122 m
18 - 24 inches	2 lb. per 400 ft. / 0.9 kg per 122 m

Sewage Sludge Ponds

- Use 60 lbs. annually / 27 kg annually per 1 million gallons of wastewater, or as needed.